




# Predictive Maintenance of Turbine Main Components

Wind Farm Operators Forum  
Gdańsk, 13-14 March 2019


# Motivation

- Reduce downtimes
- Increase Asset Lifetime
- Reduce O&M costs
- Reduce insurance costs



From full-scope to partial-scope O&M agreements (main components not included)

- Risk management
- Crane logistics
- Spare logistics
- Personnel planning
- Favorable weather windows
- Uptower repairs possible?



Predictive Maintenance of Main Components using SCADA data

# Current Development at Nispera

R&D project with Technical University of Zurich to develop models able to identify component failures before they occur. Main features:



- Automatic identification of faults using SCADA data available on the wind farm
- Advanced machine learning algorithms for fault detection and isolation
- Predict the remaining useful lifetime (RUL)

Requirements:

- High accuracy (>90%), low fraction of false alarms (<10%)
- High level of automation: automatic selection of training data sets and retraining schemes
- Applicability under different operating conditions (terrain complexity, atmospheric conditions, wind classes, etc.)
- Transferability of algorithms between turbines, so as to train the models on one turbine and apply to another similar one (in case little or no historical data is available)
- Combination with error log data from SCADA to improve fault detection

# Modeling Approach 1/2


- Model: Artificial Neural Network ANN
- Input time series:
  - Ambient Temperature,  $T_{amb}$
  - Power Output,  $P_{out}$
  - Wind Speed,  $v$
  - ... more
- Output time series:
  - Predicted Temperature,  $T_{pred}$
- Prediction error = measured – predicted temperature ( $T_{meas} - T_{pred}$ )
- Large prediction error  $\Leftrightarrow$  fault



# Modeling Approach 2/2

But how do we translate the prediction error into an alarm?

- Clustering algorithms to separate "healthy" from "faulty" data.
- 2D and 3D kmeans clustering




# Case 1: Gearbox 1/2

- Owner was not monitoring independently the temperatures of the main components
- The gearbox had to be replaced.

- Turbine offline for 28 days
- 380 MWh of Energy Loss (30'500 EUR)


*Gearbox oil temperature*



# Case 2: Gearbox 2/2

- The same Owner started to monitoring independently the temperatures of the main components
- Increase in gearbox oil temperature was detected
- The reason was quickly identified (gear oil pump)
- Major problem on gearbox was avoided, without large effort.

*Gearbox oil temperature*




# Case 3: Main Bearing

- Owner alerted OEM due to temperature increase.
- OEM performed video endoscopy.
- The damage was categorized in level 2-3 out of 5.
- Owner achieved to have component replaced before failure.
- This allowed to minimise downtime and production loss.
- Contractual availability would not be affected due to force majeure (site accessibility).



*Generator bearing front temperature*





# Case 4: Generator Cooling

- Owner alerted OEM due to temperature increase.
- OEM performed visual inspection in the turbine and found the generator cooler duct detached. (the hot air was blowing inside the nacelle instead of going outside).
- As a consequence, the turbine was operating at a curtailed power output.
- No penalisation on contractual availability !

### Weekend Order Record Form

General Ver. V4

Notification	Date	Workcenter	Tech. 1
<input type="text"/>	30.01.2018	<input type="text"/>	<input type="text"/>
Serial number	Equipment description	Tech. 2	
<input type="text"/>	<input type="text"/>	<input type="text"/>	
Time		Storage Location	Tech. 3
Hora entrada	Hora salida	<input type="text"/>	<input type="text"/>
30.01.2018 11:40	30.01.2018 13:15	1360	Tech. 4
Hora parada	Hora Marcha	<input type="text"/>	
30.01.2018 11:43	30.01.2018 13:00	<input type="text"/>	

Description of work performed:



**Temperatura alta en nacelle**  
Se encuentra acoplamiento del cooler de generador suelto, se coloca. Da alarma de oil leakage in hub y se procede a vaciar tanque de fugas unos 5 litros. El nivel de aceite de grupo hidraulico esta ok.

Counters

Main generator	<input type="text"/>
Small Generator	<input type="text"/>


8950

Generator slipping temperature




# Case 5: Generator Bearing 1/2

- Owner alerted OEM due to temperature increase.
- OEM purged the greasing system of the bearing.
- Again temperature rise observed on bearing
- When OEM inspected the turbine it was too late to do uptower repair.  
Inner ring of bearing was loose on the shaft, causing very strong vibrations, and noise!
- The generator had to be replaced.
- NOTE: Vibration monitoring system is installed on this wind turbine.



Generator bearing front temperature




- Turbine offline for 20 days
- 395 MWh of Energy Loss (32'000 EUR)

# Case 6: Generator Bearing 2/2

- Owner alerted OEM due to temperature increase.
- OEM inspected the generator.
- The Generator was repaired uptower, as the damage was not yet so advanced (replacement of bearing).
- NOTE: Vibration monitoring system is installed on this wind turbine.

- Turbine offline for 6 days
- 105 MWh of Energy Loss (8'500 EUR)

Generator bearing front temperature



# Findings & Conclusions

## FINDINGS:

Wind turbines with full-scope O&M agreement are often operated until a component fails.

- What are the predictive maintenance strategies of the O&M providers?
- What are their real incentives to avoid failures?
- Availability guarantees? Insurance coverages?

Vibration monitoring systems (CMS):

- Installation costs
- Who is responsible to analyse the data?

Periodic site inspections:

- Noise
- Greasing of bearings, oil/grease probes
- Visual inspections

## CONCLUSIONS:

- Predictive maintenance based on temperature signals from SCADA is an efficient way to prevent failures on main components
- It is beneficial if the Owner keeps an eye on the O&M provider



# Dziękuję bardzo !

Nispera AG | [nispera.com](https://nispera.com)

Hornbachstrasse 50  
8008 Zurich  
Switzerland  
T: +41 44 389 84 79  
F: +41 44 389 84 00

15.03.2019

 Nispera